

Default Price-Quality Path Annual Compliance Statement

Assessment Period

1 April 2022 – 31 March 2023

7 July 2023

Contents page

| Description | Page number |
|--|-------------|
| 1. Introduction | 03 |
| 2. Date prepared | 03 |
| 3. Wash-up amount | 04 |
| 3.1 Statement of compliance | 04 |
| 3.2 Wash-up amount calculation | 04 |
| 4. Quality standards | 08 |
| 4.1 Statement of compliance with planned interruptions quality standards | 08 |
| 4.2 Statement of compliance with unplanned interruptions | 10 |
| 4.3 Statement of compliance with extreme event standard | 11 |
| 4.4 Quality Incentive Adjustment | 12 |
| 5. Transactions | 14 |
| 6. Director's certification | 14 |
| 7. Assurance report | 14 |
| 8. Appendix A – Pass-through and recoverable costs | 15 |
| 9. Appendix B – Prices and quantities | 18 |
| 10. Appendix C - Policies and procedures for measuring planned and unplanned interruptions. | 21 |
| 11. Appendix D – SAIDI and SAIFI major events | 24 |
| 12. Appendix E – Director's certificate | 40 |
| 13. Appendix F – Assurance report | 41 |

1. Introduction

Firstlight Network (previously known as Eastland Network) is subject to price-quality regulation under Part 4 of the Commerce Act 1986. The Commerce Commission has set a Default Price-Quality Path (DPP) which applies to Eastland Network from 1 April 2020.

This annual compliance statement is published in accordance with clause 11.4 of the 2020 DPP Determination, and applies to the second assessment period, commencing 1 April 2022 and ending 31 March 2023.

2. Date prepared

This statement was prepared on 7 July 2023.

3. Wash-up amount

3.1 Statement of compliance

As demonstrated in Table 1 in Section 3.2, and consistent with clause 8.6 of the 2020 DPP Determination Firstlight Network has complied with the wash-up amount calculation for the third assessment period.

3.2 Wash-up amount calculation

Table 1

| Wash-up amount RY23 | | |
|--------------------------------|--|---------------|
| Term | Description | Value (\$000) |
| Actual allowable revenue (AAR) | <i>Sum of actual net allowable revenue, actual pass-through and recoverable costs, pass-through balance and revenue wash-up draw down amount</i> | 32,409 |
| Actual revenue (AR) | <i>Sum of actual revenue from prices plus other regulated income</i> | 30,310 |
| Revenue foregone (RV) | <i>Actual net allowable revenue x (revenue reduction percentage - 20%) when revenue reduction percentage is greater than 20%, otherwise nil</i> | - |
| Wash-up amount | AAR - AR - RV | 2,099 |

Further information supporting actual allowable revenue is included in Section 3.2.1.

Further information supporting actual revenue is included in Section 3.2.2.

Further information supporting revenue foregone is included in Section 3.2.3.

3.2.1 Wash-up amount calculation

Table 2 below shows the actual allowable revenue for the assessment period consistent with Schedule 1.6 of the 2020 DPP Determination. Below is also a CPI adjustment calculation used to calculate the Actual net allowable revenue.

Table 2

| Actual allowable revenue RY23 | | |
|---|---|---------------|
| Term | Description | Value (\$000) |
| Actual net allowable revenue previous ($ANAR_{previous}$) | $ANAR_{previous}$ is the actual net allowable revenue of the previous assessment period | 25,301 |
| ΔCPI_t | is the derived change in CPI to be applied for the assessment period | 7.10% |
| X | X Factor is the annual rate of change specified in Schedule 1.2 of the Determination | 0.00% |
| Actual net allowable revenue (ANAR) | ANAR for the third assessment period is the amount calculated using the formula $ANAR_{previous} * (1 + \Delta CPI_t) * ((1 - X))$ | 27,097 |
| Actual pass-through costs | Sum of all pass-through costs that were incurred or approved by the Commission in the assessment period | 408 |
| Actual recoverable costs | Sum of all recoverable costs that were incurred or approved by the Commission in the assessment period | 5,248 |
| Opening wash-up account balance | For the third to fifth assessment period of the DPP regulatory period, the closing wash-up account balance of the previous assessment period | (344) |
| Total actual allowable revenue (AAR) | Actual net allowable revenue + actual pass-through costs and actual recoverable costs – (pass-through balance x $(1 + 67^{th}$ percentile estimate of post-tax WACC)) | 32,409 |

| ΔCPI_{2023} | | | |
|-------------------------------|--------------|-------------------------------|------|
| Denominator | | Numerator | |
| $\text{CPI}_{\text{Jun}2021}$ | 1082 | $\text{CPI}_{\text{Jun}2022}$ | 1161 |
| $\text{CPI}_{\text{Sep}2021}$ | 1106 | $\text{CPI}_{\text{Sep}2022}$ | 1186 |
| $\text{CPI}_{\text{Dec}2021}$ | 1122 | $\text{CPI}_{\text{Dec}2022}$ | 1203 |
| $\text{CPI}_{\text{Mar}2022}$ | 1142 | $\text{CPI}_{\text{Mar}2023}$ | 1218 |
| ΔCPI_{2023} | 7.10% | | |

Further information supporting actual pass-through costs, actual recoverable costs and the pass-through balance is included in Appendix A.

3.2.2 Actual revenue

Table 3 below shows actual revenue for the assessment period consistent with clause 4.2 of the 2020 DPP Determination.

Table 3

| Actual revenue RY23 | | |
|----------------------------------|---|---------------|
| Term | Description | Value (\$000) |
| Actual revenue from prices | <i>Actual prices between 1 April 2022 and 31 March 2023 multiplied by actual quantities for the assessment period</i> | 29,963 |
| Other regulated income | <i>Other income associated with supply of electricity distribution services</i> | 348 |
| Total actual revenue (AR) | <i>Sum of actual revenue from prices plus other regulated income</i> | 30,310 |

Further information supporting actual revenue from prices is included in Appendix B.

3.2.3 Revenue foregone.

Table 4 below shows the revenue foregone consistent with clause 4.2 of the 2020 DPP Determination.

Table 1

| Revenue foregone RY23 | | |
|-------------------------------------|---|---------------|
| Term | Description | Value (\$000) |
| Actual net allowable revenue (ANAR) | <i>Amount specified as forecast net allowable revenue for the third assessment period</i> | 27,097 |
| Revenue reduction percentage (RRP) | <i>1 - (actual revenue from prices / forecast revenue from prices)</i> | 0.52% |
| Revenue foregone (RV) | <i>Actual net allowable revenue x (RRP-20%) when RRP is greater than 20%, otherwise nil</i> | - |

4. Quality standards

4.1 Statement of compliance with planned interruptions quality standards

Firstlight Network is subject to a planned accumulated SAIDI limit and a planned accumulated SAIFI limit which are assessed for the DPP regulatory period as stated in clause 9.2 of the 2020 DPP Determination.

Table 5 and Table 6 below show the planned accumulated SAIDI and SAIFI limits for Firstlight Network for the DPP regulatory period and the planned SAIDI and SAIFI assessed values for the third assessment period.

Table 5

| Planned interruptions quality standard - SAIDI | |
|---|------------------|
| Sum of planned SAIDI assessed values \leq Planned accumulated SAIDI limit | |
| Planned accumulated SAIDI limit | 1,290.68 |
| Planned SAIDI assessed value for the third assessment period | 303.19 |
| Compliance result | Compliant |

Table 6

| Planned interruptions quality standard - SAIFI | |
|---|------------------|
| Sum of planned SAIFI assessed values \leq Planned accumulated SAIFI limit | |
| Planned accumulated SAIFI limit | 7.47 |
| Planned SAIFI assessed value for the third assessment period | 2.01 |
| Compliance result | Compliant |

Further information supporting planned SAIDI and SAIFI assessed values is included in Section 4.1.1.

4.1.1 Planned SAIDI and SAIFI assessed values.

Table 7 and Table 8 below show Eastland Network's planned SAIDI and SAIFI assessed values for the assessment period.

Table 7

| Planned SAIDI assessed value RY23 | | |
|---|--|--------|
| Term | Description | Value |
| Class B non-notified interruptions | | 31.84 |
| Class B notified interruptions falling outside window | | 3.59 |
| $SAIDI_B$ | <i>Sum of Class B non-notified interruptions</i> | 35.42 |
| Class B notified interruptions falling inside window | | 103.29 |
| Class B intended interruptions cancelled without notice | | 42.07 |
| Class B intended interruptions cancelled with notice | | - |
| $SAIDI_N$ | <i>Sum of Class B notified interruptions</i> | 145.36 |
| Planned SAIDI assessed value | $SAIDI_B + (SAIDI_N / 2)$ | 108.10 |

Table 8

| Planned SAIFI assessed value RY23 | | |
|-----------------------------------|---|--------|
| Term | Description | Value |
| Planned SAIFI assessed value | <i>Sum of Class B interruptions commencing within the assessment period</i> | 0.7357 |

4.2 Statement of compliance with unplanned interruptions quality standards

As demonstrated in Table 9 below, and consistent with clause 9.7 of the 2020 DPP Determination, Firstlight Network has not complied with the unplanned interruptions SAIDI quality standard, but as shown in Table 10, complied with the unplanned interruptions SAIFI quality standard.

This statement is accompanied by Unplanned Interruption Report explaining the non-compliance with Unplanned SAIDI limit as per reporting requirements specified in clause 12.4 of the DPP Determination.

Table 9

| Unplanned interruptions quality standard RY23 - SAIDI | | |
|---|---|----------------------|
| Unplanned SAIDI assessed value \leq Unplanned SAIDI limit | | |
| Unplanned SAIDI limit | | 219.46 |
| Unplanned SAIDI assessed value | <i>Sum of normalised SAIDI values for Class C interruptions commencing within the assessment period</i> | 295.44 |
| Compliance result | | Not Compliant |

Table 10

| Unplanned interruptions quality standard RY23 - SAIFI | | |
|---|---|------------------|
| Unplanned SAIFI assessed value \leq Unplanned SAIFI limit | | |
| Unplanned SAIFI limit | | 3.1525 |
| Unplanned SAIFI assessed value | <i>Sum of normalised SAIFI values for Class C interruptions commencing within the assessment period</i> | 2.6402 |
| Compliance result | | Compliant |

Information about policies, procedures and calculations for measuring planned and unplanned interruptions during the assessment period is in Appendix C.

4.2.1 Major events

Table 11 and Table 12 below show the SAIDI and SAIFI values attributed to major events which occurred during the assessment period.

Further information about major events is included in Appendix D.

Table 11

| Unplanned SAIDI major events RY23 | | | |
|-----------------------------------|------------------|--------------------------------|----------------------------|
| Start | End | Pre-normalised unplanned SAIDI | Normalised unplanned SAIDI |
| 13/04/2022 8:30 | 13/04/2022 17:30 | 52.610 | 2.734 |
| 13/04/2022 18:30 | 14/04/2022 18:00 | 49.093 | 2.861 |
| 10/01/2023 5:00 | 10/01/2023 21:00 | 78.393 | 2.665 |
| 10/01/2023 23:00 | 11/01/2023 15:00 | 14.121 | 1.970 |
| 13/02/2023 7:00 | 13/02/2023 16:00 | 42.939 | 2.430 |
| 13/02/2023 17:00 | 14/02/2023 8:30 | 924.170 | 5.890 |
| 14/02/2023 16:00 | 15/02/2023 11:30 | 20.039 | 0.641 |
| 15/02/2023 14:30 | 16/02/2023 14:00 | 14.448 | 1.107 |

Table 12

| Unplanned SAIFI major events RY23 | | | |
|-----------------------------------|------------------|--------------------------|----------------------|
| Start | End | Pre-normalised unplanned | Normalised unplanned |
| 19/08/2022 15:30 | 20/08/2022 11:00 | 0.8326 | 0.0151 |
| 10/01/2023 5:00 | 11/01/2023 0:30 | 0.1815 | 0.0383 |
| 13/02/2023 7:00 | 13/02/2023 20:30 | 0.2424 | 0.0610 |
| 13/02/2023 21:00 | 14/02/2023 19:30 | 1.0184 | 0.0551 |

4.3 Statement of compliance with extreme event standard

As demonstrated in Table 13 below, and consistent with clause 9.9 of the 2020 DPP Determination Firstlight Network has complied with the extreme event standard.

Table 13

| Extreme event standard RY23 | |
|---|-------------------|
| Unplanned SAIDI value ≤ 120 minutes, and | |
| Number of extreme | Compliance result |
| - | Compliant |

4.4 Quality Incentive Adjustment

Table 14 below shows Firstlight Network's quality incentive adjustment for the assessment period.

Table 14

| Quality Incentive Adjustment RY23 | | |
|---|--|---------------|
| Term | Description | Value (\$000) |
| SAIDI planned adjustment | $(SAIDI_{planned, target} - SAIDI_{planned, assessed}) \times 0.5 \times IR$ | (31) |
| SAIDI unplanned adjustment | $(SAIDI_{unplanned, target} - SAIDI_{unplanned, assessed}) \times IR$ | (128) |
| Total adjustment | $SAIDI_{planned adjustment} + SAIDI_{unplanned adjustment}$ | (158) |
| Revenue at risk | $0.02 * ANAR$ | 542 |
| Total penalty/reward | | (158) |
| 67th percentile estimate of post-tax WACC | | 4.23% |
| Quality incentive adjustment | | (172) |

Table 15 below shows Firstlight Network's quality incentive adjustment inputs consistent with Schedule 4 of the 2020 DPP Determination.

Table 15

| Quality Incentive Adjustment Inputs RY23 | | | | | |
|---|---------|--------|---|---------|--------|
| Term | Units | Value | Term | Units | Value |
| SAIDI planned interruption cap | minutes | 258.14 | SAIDI unplanned interruption cap | minutes | 219.46 |
| SAIDI planned interruption collar | minutes | - | SAIDI unplanned interruption collar | minutes | - |
| SAIDI planned interruption target | minutes | 86.05 | SAIDI unplanned interruption target | minutes | 173.85 |
| Planned SAIDI assessed value | minutes | 108.10 | Unplanned SAIDI assessed value | minutes | 295.44 |
| Incentive rate | | 2,797 | | | |
| Actual net allowable revenue (ANAR) | \$000 | 27,097 | | | |
| | | | | | |
| SAIDI planned interruption target | minutes | 86 | SAIDI unplanned interruption target | minutes | 174 |
| Minimum of the planned SAIDI cap and assessed value | minutes | 108 | Minimum of the unplanned SAIDI cap and assessed value | minutes | 219 |
| Planned SAIDI subject to incentive | minutes | (22) | Unplanned SAIDI subject to incentive | minutes | (46) |
| Adjustment (IR x 0.5) | \$ | 1,399 | Adjustment (IR) | \$ | 2,797 |
| SAIDI planned adjustment | \$000 | (31) | SAIDI unplanned adjustment | \$000 | (128) |

5. Transactions

Eastland Network changed ownership on 1 April 2023 from Eastland Group to First Gas Group and changed name to Firstlight Network. First Gas Group does not own or manage any other EDBs. Apart from the acquisition by First Gas Group, Firstlight Network has not entered into any agreements with another EDB or Transpower for an amalgamation, merger, major transaction or transfer in the assessment period.

6. Director's certification

A Director's certificate in the form set out in Schedule 7 of the 2020 DPP Determination is included as Appendix E.

7. Assurance report

An assurance report meeting the requirements of Schedule 8 of the 2020 DPP Determination is included in Appendix F.

Appendix A – Pass-through and recoverable costs

Pass-through costs

Table 16

| Actual and forecast pass-through costs RY23 | | | | |
|---|----------------|------------------|---------------------------|--|
| Actual pass-through costs | Actual (\$000) | Forecast (\$000) | Forecast variance (\$000) | Explanation for variances |
| Rates on system fixed assets | 248 | 280 | (32) | Based on FY21 Actuals + 2% CPI ¹ /2 |
| Commerce Act levies | 93 | 58 | 35 | Based on FY21 Actuals + 2% CPI ¹ /2 |
| Electricity Authority levies | 51 | 62 | (11) | Based on FY21 Actuals + 2% CPI ¹ /2 |
| Utilities Disputes levies | 16 | 15 | 0 | |
| Total actual pass-through costs | 408 | 416 | (8) | |

Recoverable cost

Table 17

| Actual and forecast recoverable costs RY23 | | | | |
|--|----------------|------------------|---------------------------|---|
| Actual recoverable costs | Actual (\$000) | Forecast (\$000) | Forecast variance (\$000) | Explanation for variances |
| IRIS incentive adjustment | (741) | (741) | - | |
| Transmission charges | 5,582 | 5,582 | 0 | |
| New investment contract charges | 75 | 75 | - | |
| System operator services charges | | | - | |
| Avoided transmission charges | | | - | |
| Distributed generation allowance | 402 | 402 | (0) | |
| Claw-back | | | - | |
| Catastrophic event allowance | | | - | |
| Extended reserves allowance | | | - | |
| Quality incentive adjustment | (17) | (17) | - | |
| Capex wash-up adjustment | (79) | (79) | - | |
| Reconsideration event allowance | | | - | |
| Quality standard variation engineers fee | | | - | |
| Urgent project allowance | | | - | |
| Fire and Emergency NZ levies | 25 | 31 | (7) | Forecast based on FY21 Actuals + 2%CPI ¹ 2 |
| Innovation project allowance | | | - | |
| Total actual recoverable costs | 5,248 | 5,255 | (7) | |

Pass through balance

Table 18

| Opening wash-up account balance RY23 | | |
|--|---|---------------|
| Term | Description | Value (\$000) |
| Wash-up amount for the previous assessment period | <i>Pass-through balance for the assessment period ending 31 March 2022</i> | (317) |
| Voluntary undercharging amount foregone for the previous assessment period | <i>An estimate of the pass-through balance as at 31 March 2022</i> | - |
| 67th percentile estimate of post-tax WACC | | 4.23% |
| Opening wash-up account balance RY23 | <i>(Wash-up amount - voluntary undercharging amount foregone) x (1 + 67th percentile estimate of post-tax WACC)²</i> | (344) |

Appendix B – Prices and quantities

Table 19 shows the actual prices and quantities for actual revenue from prices for the second assessment period.

Table 19

| Actual revenue from prices RY23 | | | | |
|---------------------------------|--------|------------|-----------------|------------------------|
| Price Category | Unit | Unit price | Actual quantity | Actual revenue (\$000) |
| DOMLFC Fixed | \$/day | 0.3000 | 12,563 | 1,376 |
| DOMLFC Peak | \$/kWh | 0.1770 | 7,489,432 | 1,326 |
| DOMLFC Off Peak + Night | \$/kWh | 0.0957 | 14,993,459 | 1,435 |
| DOMLFC Uncontrolled | \$/kWh | 0.1237 | 27,748,886 | 3,433 |
| DOMLFC Controlled | \$/kWh | 0.1050 | 14,351,824 | 1,507 |
| DOMSTD Fixed | \$/day | 2.0000 | 7,793 | 5,689 |
| DOMSTD Peak | \$/kWh | 0.0778 | 7,872,514 | 612 |
| DOMSTD Off Peak + Night | \$/kWh | 0.0309 | 16,740,634 | 517 |
| DOMSTD Uncontrolled | \$/kWh | 0.0469 | 28,452,803 | 1,334 |
| DOMSTD Controlled | \$/kWh | 0.0260 | 13,970,809 | 363 |
| COM0050 Fixed | \$/day | 2.3000 | 4,626 | 3,884 |
| COM0050 Peak | \$/kWh | 0.0674 | 2,254,627 | 152 |
| COM0050 Off Peak + Night | \$/kWh | 0.0270 | 5,375,066 | 145 |
| COM0050 Uncontrolled | \$/kWh | 0.0400 | 29,533,739 | 1,181 |
| COM0050 Controlled | \$/kWh | 0.0241 | 2,293,669 | 55 |
| COM0100 Fixed | \$/day | 8.3500 | 429 | 1,307 |
| COM0100 Peak | \$/kWh | 0.0931 | 1,452,644 | 135 |
| COM0100 Off Peak + Night | \$/kWh | 0.0373 | 3,915,210 | 146 |
| COM0100 Uncontrolled | \$/kWh | 0.0524 | 18,027,532 | 945 |
| COM0100 Controlled | \$/kWh | 0.0345 | 379,288 | 13 |
| COM0300 Fixed | \$/day | 16.0000 | 116 | 678 |
| COM0300 Morning Peak | \$/kWh | 0.0350 | 2,890,747 | 101 |
| COM0300 Night | \$/kWh | 0.0154 | 2,511,762 | 39 |
| COM0300 Evening Peak | \$/kWh | 0.0375 | 1,744,335 | 65 |
| COM0300 Off Peak | \$/kWh | 0.0278 | 3,531,970 | 98 |
| COM0300 Uncontrolled | \$/kWh | 0.0414 | 10,409,521 | 431 |
| COM0500 Fixed | \$/day | 32.0000 | 23 | 267 |
| COM0500 Morning Peak | \$/kWh | 0.0350 | 2,370,558 | 83 |
| COM0500 Night | \$/kWh | 0.0154 | 2,622,475 | 40 |
| COM0500 Evening Peak | \$/kWh | 0.0375 | 1,488,760 | 56 |
| COM0500 Off Peak | \$/kWh | 0.0278 | 2,976,218 | 83 |
| COM1000 Fixed | \$/day | 50.0000 | 24 | 435 |
| COM1000 Morning Peak | \$/kWh | 0.0350 | 7,231,914 | 253 |
| COM1000 Night | \$/kWh | 0.0154 | 8,212,224 | 126 |
| COM1000 Evening Peak | \$/kWh | 0.0375 | 4,661,284 | 175 |
| COM1000 Off Peak | \$/kWh | 0.0278 | 9,293,289 | 258 |
| COM4500 Fixed | \$/day | 140.0000 | 3 | 153 |
| COM4500 Morning Peak | \$/kWh | 0.0343 | 5,518,783 | 189 |

Table 19 continued

| Actual revenue from prices RY23 | | | | |
|--|--------|------------|-----------------|------------------------|
| Price Category | Unit | Unit price | Actual quantity | Actual revenue (\$000) |
| COM4500 Night | \$/kWh | 0.0150 | 6,986,258 | 105 |
| COM4500 Evening Peak | \$/kWh | 0.0366 | 3,874,397 | 142 |
| COM4500 Off Peak | \$/kWh | 0.0274 | 7,304,542 | 200 |
| COM6500 Fixed | \$/day | 200.0000 | 1 | 73 |
| COM6500 Morning Peak | \$/kWh | 0.0343 | 1,847,839 | 63 |
| COM6500 Night | \$/kWh | 0.0150 | 1,503,001 | 23 |
| COM6500 Evening Peak | \$/kWh | 0.0366 | 746,508 | 27 |
| COM6500 Off Peak | \$/kWh | 0.0274 | 2,014,594 | 55 |
| GEN6500 Fixed | \$/day | 104.9645 | 1 | 38 |
| GEN6500 Uncontrolled | \$/kWh | 0.0309 | 98,971 | 3 |
| OTH0003 Fixed | \$/day | 0.4918 | 81 | 15 |
| OTH0003 Uncontrolled | \$/kWh | 0.1042 | 220,506 | 23 |
| DUML Fixed | \$/day | 0.0608 | 5,146 | 114 |
| DUML Uncontrolled | \$/kWh | 0.0729 | 1,471,197 | 107 |
| STLGM Fixed | \$/day | 0.0665 | 242 | 6 |
| STLGM Uncontrolled | \$/kWh | 0.0729 | 37,258 | 3 |
| DOMLFC Peak - FY22 wash-ups | \$/kWh | 0.2074 | 1,125,379 | 233 |
| DOMLFC Off Peak + Night - FY22 wash-ups | \$/kWh | 0.1157 | 3,168,076 | 367 |
| DOMLFC Uncontrolled - FY22 wash-ups | \$/kWh | 0.1442 | (4,927,455) | (711) |
| DOMLFC Controlled - FY22 wash-ups | \$/kWh | 0.0759 | 500,499 | 38 |
| DOMSTD Peak - FY22 wash-ups | \$/kWh | 0.0897 | 1,635,489 | 147 |
| DOMSTD Off Peak + Night - FY22 wash-ups | \$/kWh | 0.0359 | 4,099,045 | 147 |
| DOMSTD Uncontrolled - FY22 wash-ups | \$/kWh | 0.0528 | (5,565,791) | (294) |
| DOMSTD Controlled - FY22 wash-ups | \$/kWh | 0.0294 | 169,437 | 5 |
| COM0050 Peak - FY22 wash-ups | \$/kWh | 0.0807 | 387,027 | 31 |
| COM0050 Off Peak + Night - FY22 wash-ups | \$/kWh | 0.0323 | 1,023,114 | 33 |
| COM0050 Uncontrolled - FY22 wash-ups | \$/kWh | 0.0474 | (1,515,338) | (72) |
| COM0050 Controlled - FY22 wash-ups | \$/kWh | 0.0284 | 35,327 | 1 |
| COM0100 Peak - FY22 wash-ups | \$/kWh | 0.1141 | 215,181 | 25 |
| COM0100 Off Peak + Night - FY22 wash-ups | \$/kWh | 0.0457 | 562,938 | 26 |
| COM0100 Uncontrolled - FY22 wash-ups | \$/kWh | 0.0643 | (896,445) | (58) |
| COM0100 Controlled - FY22 wash-ups | \$/kWh | 0.0423 | (14,216) | (1) |
| COM0300 Morning Peak - FY22 wash-ups | \$/kWh | 0.0429 | (122,209) | (5) |
| COM0300 Night - FY22 wash-ups | \$/kWh | 0.0188 | (12,787) | (0) |
| COM0300 Evening Peak - FY22 wash-ups | \$/kWh | 0.0460 | (81,721) | (4) |
| COM0300 Off Peak - FY22 wash-ups | \$/kWh | 0.0340 | (52,207) | (2) |
| COM0300 Uncontrolled - FY22 wash-ups | \$/kWh | 0.0507 | (481,510) | (24) |
| COM4500 Morning Peak - FY22 wash-ups | \$/kWh | 0.0420 | 167,243 | 7 |
| COM4500 Night - FY22 wash-ups | \$/kWh | 0.0184 | 263,430 | 5 |
| COM4500 Evening Peak - FY22 wash-ups | \$/kWh | 0.0449 | 141,449 | 6 |
| COM4500 Off Peak - FY22 wash-ups | \$/kWh | 0.0335 | 238,684 | 8 |
| OTH0003 Uncontrolled - FY22 wash-ups | \$/kWh | 0.1276 | (935) | (0) |
| DUML Uncontrolled - FY22 wash-ups | \$/kWh | 0.0872 | (128,760) | (11) |
| STLGM Uncontrolled - FY22 wash-ups | \$/kWh | 0.0872 | (869) | (0) |
| Tariff switches variances | | | | (18) |
| Total actual revenue from prices | | | | 29,963 |

Table 20 shows the forecast revenue from prices for the second assessment period from the price setting compliance statement.

Table 20

| Forecast revenue from prices RY23 | |
|------------------------------------|--------|
| Total forecast revenue from prices | 30,119 |

Appendix C - Policies and procedures for measuring planned and unplanned interruptions.

Following is a summary of policies and procedures used by Firstlight Network during the assessment period for capturing, recording and calculating class B and class C interruptions and planned and unplanned SAIDI and SAIFI assessed values.

Processing planned and intended interruptions.

1. Project manager issues a job to a network approved contractor.
2. The network approved contractor or project manager completes a work application form for a shutdown and emails it to the control room.
3. Work application is assessed and checked by the Network Control Manager or the Senior control room operator.
4. The information from the approved work application is entered into outage manager (an access database) as a new record.
5. When the data has been entered into outage manager an email is generated about the planned shutdown and sent to all retailers and MEPs.
6. Attached with the work application is a schematic plan of the work site which includes the transformers that will be affected by the shutdown. These transformers are entered into outage manager. This will generate a spreadsheet that will have a list of the number of ICPs (customers) affected. This is generated from ESRI/SAP system and these are the customers that are used as a basis for the customer minute calculations.
7. The outage is then entered onto the Firstlight Network website.
8. When the planned outage occurs, the switching is completed by the controller.
9. The controller completes an outage information form.
10. The outage information form is then checked by another controller to verify the information is correct.
11. The outage form is entered into the SAIDI/SAIFI model. This is an excel model that calculates SAIDI and SAIFI in accordance with the regulations set out in Electricity Distribution Services Default Price-Quality Path Determination 2020.
12. The Pricing and Regulatory Manager would review Pricing and Regulatory Analyst's input to avoid errors.
13. Regulatory and Pricing Analyst to check the monthly data. These checks include.

- a. Cross check with outage manager to ensure all outages entered into outage manager are in the SAIDI SAIFI model.
 - b. Cross check with outages displayed on website to ensure all outages entered onto website are in the SAIDI SAIFI model.
 - c. Cross check on notified interruptions with the control room email and website notification to ensure that they comply with the 10-day notification period.
14. The Regulatory and Pricing Analyst is to prepare monthly SAIDI SAIFI reports and present them to the Network team during the third week of the following month.
 15. General Manager Networks to include the monthly SAIDI SAIFI reports in the monthly board papers.

Processing unplanned interruptions

1. An unplanned interruption occurs. The fault trips part of the network and this is alerted to the duty controller.
2. The controller completes the fault switching and the outage information form.
3. The outage form is then checked by another controller.
4. The outage form is entered into the SAIDI/SAIFI model. This is an excel model that calculates SAIDI and SAIFI in accordance with the regulations set out in Electricity Distribution Services Default Price-Quality Path Determination 2020
5. The Regulatory and Pricing Analyst is to prepare monthly SAIDI SAIFI reports and present them to the Network team during the third week of the following month.
6. General Manager Networks to include the monthly SAIDI SAIFI reports in the monthly board papers.

Numbers of customers used for switching sheets throughout the year.

At the start of each regulatory period (1 April) the information office is responsible for completing the customer numbers as at 1 April. These customer numbers will be the ones that are used for the regulatory period and are to be used while completing the outage data forms.

Firstlight Network understands that throughout the year there will be customers disconnected from the network or new customers connections. However, the effort

required to track these changes and update customer maps for customer minute purposes does not seem justified so Firstlight Network will only use this one set of customer numbers for the entire period.

ICP count

The average customer numbers that were generated from Gentrack (billing system) as part of billing are to be used.

The definition for a customer is: Means any person who is supplied with electricity but does not include any electricity generator or any electricity distributor or retailer.

This means that ICP status AC (= Active) is to be included in the average customer numbers for the year.

Appendix D – SAIDI and SAIFI major events

The below table 21 and 22 show the normalisation of the SAIDI and SAIFI major events that took place during the assessment period, consistent with Schedule 3.2 of the 2020 DPP Determination.

Below each table there is further information pertaining to the major event including location of the event, equipment involved, Firstlight Network's response and future step to avoid similar event occurring in the future.

Detailed analysis was only done for the main contributing outages to the SAIDI or SAIFI major event. An outage with more than 20% weighting towards the raw SAIDI or SAIFI number was included in the analysis.

Table 21

| Normalisation of unplanned SAIDI major events RY23 | | | |
|--|----------------------|--|---|
| SAIDI unplanned boundary value | | | 13.10 |
| 1/48th of the SAIDI unplanned boundary value | 13/04/2022 | | |
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 13/04/2022 8:30 | 7.566 | 0.273 |
| 0.27 | 13/04/2022 9:00 | 7.919 | 0.273 |
| 0.27 | 13/04/2022 13:00 | 2.179 | 0.273 |
| 0.27 | 13/04/2022 13:30 | 3.679 | 0.273 |
| 0.27 | 13/04/2022 14:00 | 14.747 | 0.273 |
| 0.27 | 13/04/2022 14:30 | 1.756 | 0.273 |
| 0.27 | 13/04/2022 15:00 | 2.228 | 0.273 |
| 0.27 | 13/04/2022 16:00 | 0.005 | 0.005 |
| 0.27 | 13/04/2022 16:30 | 2.754 | 0.273 |
| 0.27 | 13/04/2022 17:00 | 4.486 | 0.273 |
| 0.27 | 13/04/2022 17:30 | 4.950 | 0.273 |
| Total | | 52.268 | 2.734 |

| SAIDI Major Event Information | |
|---|--|
| Cause | Wind and storms for several days- Multiple faults. Major Weather event - April |
| Start Date | 13/04/2022 |
| Start Time | 02:08 PM |
| End Date | 15/04/2022 |
| End Time | 12:58 PM |
| SAIDI value of major event before replacement | 6.1559 |
| SAIDI value of major event | 0.3207 |
| Location of SAIDI major event | All Inland Feeder |
| Main equipment involved in SAIDI major event | 11kV Feeder |
| How Eastland Network responded to the event | Major Wind event, limited resources, and attended multiple sites as soon as possible to ascertain the event, restore power if possible, and make it safe. Multiple trees through lines |
| Mitigating factors that may have prevented or minimised the major event | More resources are needed, as are larger forestry corridors. |
| Steps taken to mitigate the risk of future major events | Working more closely with Forestry owners to maintain better clearances. |

| SAIDI Major Event Information | |
|---|---|
| Cause | Severe wind caused clashing span and burnt down line(huge span). Major Storm event April. |
| Start Date | 13/04/2022 |
| Start Time | 09:21 AM |
| End Date | 18/04/2022 |
| End Time | 04:28 PM |
| SAIDI value of major event before replacement | 4.9309 |
| SAIDI value of major event | 0.2560 |
| Location of SAIDI major event | Waikura, Lottin point |
| Main equipment involved in SAIDI major event | 11kV Conductor |
| How Eastland Network responded to the event | Feeder tripped, limited resources, remote location. All power was restored with the installation of a generator the next day. |
| Mitigating factors that may have prevented or minimised the major event | The original fault was due to a replacement conductor that was not fit for its intended purpose |
| Steps taken to mitigate the risk of future major events | Found original repairs done after 1st fault, not correct conductor size. Pole construction/configuration to be changed. |

| SAIDI Major Event Information | |
|---|--|
| Cause | Severe wind caused clashing span and burnt down line(huge span). Major April Weather event |
| Start Date | 13/04/2022 |
| Start Time | 05:57 PM |
| End Date | 15/04/2022 |
| End Time | 05:31 PM |
| SAIDI value of major event before replacement | 5.0092 |
| SAIDI value of major event | 0.2590 |
| Location of SAIDI major event | Whole of Tauwhareparae Rd |
| Main equipment involved in SAIDI major event | 11kV Conductor |
| How Eastland Network responded to the event | Feeder Tripped at night, sent fault man the next day when light. It took 2 days to repair. |
| Mitigating factors that may have prevented or minimised the major event | More resources needed and larger forestry corridors. |
| Steps taken to mitigate the risk of future major events | Working more closely with Forestry owners to maintain better clearances. |

| SAIDI Major Event Information | |
|---|---|
| Cause | Trees came through line. April Weather event |
| Start Date | 13/04/2022 |
| Start Time | 05:01 PM |
| End Date | 14/04/2022 |
| End Time | 09:44 AM |
| SAIDI value of major event before replacement | 8.6741 |
| SAIDI value of major event | 0.2347 |
| Location of SAIDI major event | Raupunga |
| Main equipment involved in SAIDI major event | 11kV Feeder Fault |
| How Eastland Network responded to the event | Feeder tripped at night. Patrolled the next day and found trees in line. Power Restored. |
| Mitigating factors that may have prevented or minimised the major event | More resources are needed and larger forestry corridors. Looking at sectionalising feeders with the installation of permanent generators. |
| Steps taken to mitigate the risk of future major events | Working more closely with Forestry owners to maintain better clearances. The ongoing investigation of generator solutions. |

| SAIDI Major Event Information | |
|---|--|
| Cause | High wind caused multiple trippings (x4), closed in rest day |
| Start Date | 13/04/2022 |
| Start Time | 02:17 PM |
| End Date | 14/04/2022 |
| End Time | 10:08 AM |
| SAIDI value of major event before replacement | 5.3348 |
| SAIDI value of major event | 0.2791 |
| Location of SAIDI major event | Tuai |
| Main equipment involved in SAIDI major event | 11kV conductor clashing |
| How Eastland Network responded to the event | Waited for Wind to abate |
| Mitigating factors that may have prevented or minimised the major event | Weather Event can't be predicted |
| Steps taken to mitigate the risk of future major events | Line to be droned to find possible clashing spans |

| SAIDI Major Event Information | |
|---|---|
| Cause | Strong winds and Rain snapped pole and broke wires |
| Start Date | 13/04/2022 |
| Start Time | 08:33 AM |
| End Date | 14/04/2022 |
| End Time | 05:09 PM |
| SAIDI value of major event before replacement | 7.8339 |
| SAIDI value of major event | 0.3958 |
| Location of SAIDI major event | Rangitukia |
| Main equipment involved in SAIDI major event | 11kV Pole/Conductor - J2202 |
| How Eastland Network responded to the event | Feeder tripped; the road was closed, so we could not patrol. It took 24 hours to gain access to the site. Isolated tap offline and restored power to 50% of the consumers. Made temporary repairs and returned to fix them. |
| Mitigating factors that may have prevented or minimised the major event | Access was the biggest issued at this site as the road was impassable. |
| Steps taken to mitigate the risk of future major events | Pole testing regime in progress in the area, not completed yet. Prioritise pole testing locations based on fault data. |

| SAIDI Major Event Information | |
|---|--|
| Cause | Trees vs lines & poles-multi sites wind/storm battered area. Major April Storm |
| Start Date | 13/04/2022 |
| Start Time | 02:09 PM |
| End Date | 27/04/2022 |
| End Time | 04:22 PM |
| SAIDI value of major event before replacement | 7.4967 |
| SAIDI value of major event | 0.3559 |
| Location of SAIDI major event | Mata Rd |
| Main equipment involved in SAIDI major event | 11kV Conductor - Multiple Faults |
| How Eastland Network responded to the event | Feeder tripped, limited resources could not get to site until next day. Isolated areas to be repaired and installed 1 x generator and used consumers generator. One area could not be supplied (21 customers), no more generators available. |
| Mitigating factors that may have prevented or minimised the major event | More resource needed and larger forestry corridors. |
| Steps taken to mitigate the risk of future major events | Working more closely with Forestry owners to maintain better clearances. Purchased additional 85kVA generator for this type of fault. |

| 1/48th of the SAIDI unplanned boundary value | 13/04/2022 to 14/04/2022 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 13/04/2022 18:30 | 37.705 | 0.273 |
| 0.27 | 13/04/2022 19:00 | 0.821 | 0.273 |
| 0.27 | 13/04/2022 20:00 | 0.005 | 0.005 |
| 0.27 | 13/04/2022 20:30 | 4.188 | 0.273 |
| 0.27 | 13/04/2022 21:30 | 0.022 | 0.022 |
| 0.27 | 13/04/2022 22:00 | 0.203 | 0.203 |
| 0.27 | 13/04/2022 22:30 | 1.328 | 0.273 |
| 0.27 | 14/04/2022 0:00 | 1.168 | 0.273 |
| 0.27 | 14/04/2022 0:30 | 1.762 | 0.273 |
| 0.27 | 14/04/2022 6:00 | 0.368 | 0.273 |
| 0.27 | 14/04/2022 8:30 | 0.031 | 0.031 |
| 0.27 | 14/04/2022 9:30 | 0.005 | 0.005 |
| 0.27 | 14/04/2022 10:00 | 0.001 | 0.001 |
| 0.27 | 14/04/2022 14:00 | 0.027 | 0.027 |
| 0.27 | 14/04/2022 14:30 | 0.043 | 0.043 |
| 0.27 | 14/04/2022 15:00 | 0.014 | 0.014 |
| 0.27 | 14/04/2022 15:30 | 0.416 | 0.273 |
| 0.27 | 14/04/2022 16:00 | 0.618 | 0.273 |
| 0.27 | 14/04/2022 17:00 | 0.045 | 0.045 |
| 0.27 | 14/04/2022 18:00 | 0.005 | 0.005 |
| Total | | 48.775 | 2.858 |

| SAIDI Major Event Information | |
|---|---|
| Cause | High winds caused wires to come down. April Storm Event |
| Start Date | 13/04/2022 |
| Start Time | 06:32 PM |
| End Date | 14/04/2022 |
| End Time | 03:09 PM |
| SAIDI value of major event before replacement | 33.7845 |
| SAIDI value of major event | 1.9797 |
| Location of SAIDI major event | Mahia area/Mahanga |
| Main equipment involved in SAIDI major event | 11kV Conductor |
| How Eastland Network responded to the event | Feeder tripped and found conductor fell at the start of the feeder. The back-up generator at Mahia failed to close. The generator was repaired the next day and power was restored to the customer, and then the fault was fixed. |
| Mitigating factors that may have prevented or minimised the major event | Unusual fault on generator. |
| Steps taken to mitigate the risk of future major events | Updated generator maintenance plan. |

| 1/48th of the SAIDI unplanned boundary value | 10/01/2023 | | |
|--|----------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 10/01/2023 5:00 | 1.164 | 0.273 |
| 0.27 | 10/01/2023 5:30 | 0.687 | 0.273 |
| 0.27 | 10/01/2023 8:00 | 18.918 | 0.273 |
| 0.27 | 10/01/2023 8:30 | 0.146 | 0.146 |
| 0.27 | 10/01/2023 11:00 | 0.062 | 0.062 |
| 0.27 | 10/01/2023 11:30 | 2.088 | 0.273 |
| 0.27 | 10/01/2023 14:30 | 0.333 | 0.273 |
| 0.27 | 10/01/2023 18:00 | 2.952 | 0.273 |
| 0.27 | 10/01/2023 19:00 | 14.418 | 0.273 |
| 0.27 | 10/01/2023 20:00 | 10.082 | 0.273 |
| 0.27 | 10/01/2023 21:00 | 27.036 | 0.273 |
| Total | | 77.885 | 2.664 |

| SAIDI Major Event Information | |
|---|--|
| Cause | 3 different faults with tree through lines at all locations, Paremata Rd, Arakihi Rd and Tauwhareparae Rd. No Access biggest factor in the time it took to restore power. (Cyclone Hale) |
| Start Date | 10/01/2023 |
| Start Time | 05:59 AM |
| End Date | 16/01/2023 |
| End Time | 04:56 PM |
| SAIDI value of major event before replacement | 19.6055 |
| SAIDI value of major event | 0.6706 |
| Location of SAIDI major event | Tauwhareparae Rd |
| Main equipment involved in SAIDI major event | 11kV Lines and Poles |
| How Eastland Network responded to the event | Feeder Tripped, Multiple Trippings, Faultman dispatched, found trees through the line and damaged Poles and Lines at 2 locations. Isolated areas and made repairs. Access to the top area prevented restoration for 3 days. When access became available found an additional fault at the top. |
| Mitigating factors that may have prevented or minimised the major event | Out of our control, road access and no helicopter flying prevented earlier inspection and restoration. |
| Steps taken to mitigate the risk of future major events | Liaising with GDC, (roading corridor manager) about road condition and access. |

| 1/48th of the SAIDI unplanned boundary value | 10/01/2023 to 11/01/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 10/01/2023 23:00 | 2.270 | 0.273 |
| 0.27 | 11/01/2023 0:30 | 9.067 | 0.273 |
| 0.27 | 11/01/2023 8:00 | 0.222 | 0.222 |
| 0.27 | 11/01/2023 9:30 | 0.989 | 0.273 |
| 0.27 | 11/01/2023 10:30 | 0.263 | 0.263 |
| 0.27 | 11/01/2023 13:00 | 0.259 | 0.259 |
| 0.27 | 11/01/2023 13:30 | 0.452 | 0.273 |
| 0.27 | 11/01/2023 14:00 | 0.013 | 0.013 |
| 0.27 | 11/01/2023 15:00 | 0.939 | 0.273 |
| 0.27 | 11/01/2023 17:00 | 0.369 | 0.273 |
| 0.27 | 11/01/2023 17:30 | 1.681 | 0.273 |
| Total | | 16.523 | 2.667 |

| SAIDI Major Event Information | |
|---|--|
| Cause | Found a tree broken, had fallen through a conductor |
| Start Date | 11/01/2023 |
| Start Time | 12:42 AM |
| End Date | 11/01/2023 |
| End Time | 06:06 AM |
| SAIDI value of major event before replacement | 9.0668 |
| SAIDI value of major event | 1.4634 |
| Location of SAIDI major event | Campion Area |
| Main equipment involved in SAIDI major event | 11kV clashing of lines |
| How Eastland Network responded to the event | Sent fault man to patrol line next morning and closed feeder in. Found tree branch has clashed line. No fault man attended at the time because of Cyclone Hale. |
| Mitigating factors that may have prevented or minimised the major event | Under normal circumstances, we would have sent out a fault man the same night, but because of safety regarding the Cyclone no one was sent. |
| Steps taken to mitigate the risk of future major events | Safety policy will not be changing. |

| 1/48th of the SAIDI unplanned boundary value | 13/02/2023 | | |
|--|----------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 13/02/2023 7:00 | 2.116 | 0.273 |
| 0.27 | 13/02/2023 8:00 | 0.034 | 0.034 |
| 0.27 | 13/02/2023 8:30 | 0.037 | 0.037 |
| 0.27 | 13/02/2023 9:00 | 0.038 | 0.038 |
| 0.27 | 13/02/2023 10:30 | 0.225 | 0.225 |
| 0.27 | 13/02/2023 11:00 | 1.794 | 0.273 |
| 0.27 | 13/02/2023 11:30 | 0.178 | 0.178 |
| 0.27 | 13/02/2023 12:00 | 0.255 | 0.255 |
| 0.27 | 13/02/2023 14:00 | 0.020 | 0.020 |
| 0.27 | 13/02/2023 14:30 | 3.375 | 0.273 |
| 0.27 | 13/02/2023 15:00 | 0.538 | 0.273 |
| 0.27 | 13/02/2023 15:30 | 2.595 | 0.273 |
| 0.27 | 13/02/2023 16:00 | 31.455 | 0.273 |
| Total | | 42.660 | 2.425 |

| SAIDI Information | |
|---|--|
| Cause | Tree through line, Cyclone Gabrielle |
| Start Date | 13/02/2023 |
| Start Time | 04:21 PM |
| End Date | 15/02/2023 |
| End Time | 04:31 PM |
| SAIDI value of major event before replacement | 31.4537 |
| SAIDI value of major event | 1.7879 |
| Location of SAIDI major event | Tiki Tiki |
| Main equipment involved in SAIDI major event | 11kV Line - trees |
| How Eastland Network responded to the event | No access could not get to sites to isolate fault. |
| Mitigating factors that may have prevented or minimised the major event | Access prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| 1/48th of the SAIDI unplanned boundary value | 13/02/2023 to 14/02/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 13/02/2023 17:00 | 138.106 | 0.273 |
| 0.27 | 13/02/2023 17:30 | 9.593 | 0.273 |
| 0.27 | 13/02/2023 18:00 | 45.124 | 0.273 |
| 0.27 | 13/02/2023 18:30 | 0.393 | 0.273 |
| 0.27 | 13/02/2023 19:00 | 42.634 | 0.273 |
| 0.27 | 13/02/2023 19:30 | 35.365 | 0.273 |
| 0.27 | 13/02/2023 20:00 | 0.856 | 0.273 |
| 0.27 | 13/02/2023 20:30 | 132.099 | 0.273 |
| 0.27 | 13/02/2023 21:00 | 19.702 | 0.273 |
| 0.27 | 13/02/2023 21:30 | 85.624 | 0.273 |
| 0.27 | 13/02/2023 22:00 | 5.192 | 0.273 |
| 0.27 | 13/02/2023 22:30 | 127.961 | 0.273 |
| 0.27 | 13/02/2023 23:00 | 62.167 | 0.273 |
| 0.27 | 13/02/2023 23:30 | 54.633 | 0.273 |
| 0.27 | 14/02/2023 0:00 | 30.524 | 0.273 |
| 0.27 | 14/02/2023 2:00 | 42.943 | 0.273 |
| 0.27 | 14/02/2023 2:30 | 24.458 | 0.273 |
| 0.27 | 14/02/2023 3:00 | 38.674 | 0.273 |
| 0.27 | 14/02/2023 3:30 | 9.455 | 0.273 |
| 0.27 | 14/02/2023 5:30 | 0.621 | 0.273 |
| 0.27 | 14/02/2023 6:30 | 11.891 | 0.273 |
| 0.27 | 14/02/2023 8:30 | 0.158 | 0.158 |
| Total | | 918.174 | 5.889 |

| SAIDI Information | |
|---|--|
| Cause | Spans down - Cyclone Gabrielle |
| Start Date | 17/02/2023 |
| Start Time | 10:43 PM |
| End Date | 17/02/2023 |
| End Time | 07:10 PM |
| SAIDI value of major event before replacement | 37.1577 |
| SAIDI value of major event | 0.2371 |
| Location of SAIDI major event | Kanakania |
| Main equipment involved in SAIDI major event | Tree through 11kV line |
| How Eastland Network responded to the event | Fault at start of feeder with many customers. Could not access because of flooded bridge. |
| Mitigating factors that may have prevented or minimised the major event | Access prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Cyclone Gabrielle- multiple poles down |
| Start Date | 13/02/2023 |
| Start Time | 08:59 PM |
| End Date | 1/03/2023 |
| End Time | 04:51 PM |
| SAIDI value of major event before replacement | 59.1442 |
| SAIDI value of major event | 0.3792 |
| Location of SAIDI major event | Te Arai |
| Main equipment involved in SAIDI major event | Poles and Conductor down - slips |
| How Eastland Network responded to the event | Multiple faults along feeder with multiple access issues. |
| Mitigating factors that may have prevented or minimised the major event | Access prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|---|
| Cause | Tree through line, install generator |
| Start Date | 13/02/2023 |
| Start Time | 08:51 PM |
| End Date | 22/02/2023 |
| End Time | 05:18 PM |
| SAIDI value of major event before replacement | 32.7891 |
| SAIDI value of major event | 0.2094 |
| Location of SAIDI major event | All Whatatutu |
| Main equipment involved in SAIDI major event | Tree through line |
| How Eastland Network responded to the event | Large spur line with no back feed. Installed generator at the site and went back to repair. Access was a problem for the generator and restoration. Needed good weather for a helicopter for contractors to be flown to the site for repairs. |
| Mitigating factors that may have prevented or minimised the major event | Access and bad weather, prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Tree through lines, poles slips - Cyclone Gabrielle |
| Start Date | 13/02/2023 |
| Start Time | 05:13 PM |
| End Date | 13/03/2023 |
| End Time | 04:32 PM |
| SAIDI value of major event before replacement | 53.5494 |
| SAIDI value of major event | 0.3432 |
| Location of SAIDI major event | Tauwhareparae Rd |
| Main equipment involved in SAIDI major event | Tree through line - slips |
| How Eastland Network responded to the event | No access to site, could not install generator until fault could be fixed. |
| Mitigating factors that may have prevented or minimised the major event | Fault on spur line with many customers. Access prevented quick restoration. Could not install generator. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|---|
| Cause | Slips and tress through the line - GAB |
| Start Date | 13/02/2023 |
| Start Time | 12:28 PM |
| End Date | 26/02/2023 |
| End Time | 09:33 AM |
| SAIDI value of major event before replacement | 65.6721 |
| SAIDI value of major event | 0.4194 |
| Location of SAIDI major event | Waipiro Bay |
| Main equipment involved in SAIDI major event | Broken 11kV Wires - tree through line |
| How Eastland Network responded to the event | Multiple faults in the area, including trees through line and slip on the State highway access road. Further faults at Makarika limited the ability to back feed from Ruatoria or Tokomaru Bay. |
| Mitigating factors that may have prevented or minimised the major event | Because of multiple feeder faults and access issues restoration took longer. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Slip brought pole down |
| Start Date | 13/02/2023 |
| Start Time | 06:29 PM |
| End Date | 14/03/2023 |
| End Time | 04:48 PM |
| SAIDI value of major event before replacement | 47.8637 |
| SAIDI value of major event | 0.3070 |
| Location of SAIDI major event | Anaura Bay |
| Main equipment involved in SAIDI major event | 11kV Pole |
| How Eastland Network responded to the event | Multiple faults in the area, including slip on the Satae highway, had no road access. Further faults at Mata and Tolaga Bay limited the ability to back feed and no access due to bridge and back road being inaccessible. |
| Mitigating factors that may have prevented or minimised the major event | If we had road access power would have been restored earlier. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Trees through line - GAB |
| Start Date | 13/02/2023 |
| Start Time | 05:25 PM |
| End Date | 27/02/2023 |
| End Time | 01:26 PM |
| SAIDI value of major event before replacement | 82.8524 |
| SAIDI value of major event | 0.4258 |
| Location of SAIDI major event | Raupunga, Kotemaori, Putere |
| Main equipment involved in SAIDI major event | 11kV wires down |
| How Eastland Network responded to the event | Trees through the line at the start of the Raupunga Feeder. No access, lagre numbers because normal back feed (Frasertown) not available. Limited ability to restore power to everyone until fault was fixed. Access was not available for four days with large number of consumers off. |
| Mitigating factors that may have prevented or minimised the major event | If we had road access or back up feed had not failed and power would have been restored earlier. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Multiple faults, install jumpers on to 50kV line - GAB |
| Start Date | 13/02/2023 |
| Start Time | 10:53 PM |
| End Date | 18/02/2023 |
| End Time | 01:50 PM |
| SAIDI value of major event before replacement | 41.6098 |
| SAIDI value of major event | 0.2669 |
| Location of SAIDI major event | Frasertown |
| Main equipment involved in SAIDI major event | 11kV multiple faults wires and poles down |
| How Eastland Network responded to the event | No access could not get to sites. Due to other faults unable to backfeed into area. |
| Mitigating factors that may have prevented or minimised the major event | Because of multiple feeder faults and access issues restoration took longer. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI and SAIFI Information | |
|---|---|
| Cause | Cyclone Gabrielle caused conductor to clash |
| Start Date | 13/02/2023 |
| Start Time | 10:46 PM |
| End Date | 13/02/2023 |
| End Time | 11:31 PM |
| SAIDI value of major event before replacement | 36.5036 |
| SAIDI value of major event | 0.2341 |
| SAIFI value of major event before replacement | 0.8112 |
| SAIFI value of major event | 0.0441 |
| Location of SAIDI major event | All Gisborne & East Coast |
| Main equipment involved in SAIDI major event | 110kV Wires clashing |
| How Eastland Network responded to the event | We initiated the network 110kV outage procedure by analysing the SCADA data from the fault. It was ascertained it was a phase to phase on both circuits clashing. We could then close circuit back in within 45 minutes |
| Mitigating factors that may have prevented or minimised the major event | We have changed the phasing so the clashes are phase to phase and the circuit can be reclosed without patrolling. Reducing the outage time considerably. |
| Steps taken to mitigate the risk of future major events | Created the process above to minimise when this occurs as a result of extreme weather events. |

| SAIDI Information | |
|---|--|
| Cause | Trees through line, Cyclone Gabrielle |
| Start Date | 13/02/2023 |
| Start Time | 11:34 AM |
| End Date | 21/02/2023 |
| End Time | 05:40 PM |
| SAIDI value of major event before replacement | 34.2953 |
| SAIDI value of major event | 0.2190 |
| Location of SAIDI major event | Tiniroto |
| Main equipment involved in SAIDI major event | Tree through line and slips |
| How Eastland Network responded to the event | No access, could not get to sites. Due to other faults unable to backfeed into area. |
| Mitigating factors that may have prevented or minimised the major event | Because of multiple feeder faults and access issues restoration took longer. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI and SAIFI Information | |
|---|---|
| Cause | Multiple feeder faults/tripping from mains & Gen including 50kV and 11kV |
| Start Date | 13/02/2023 |
| Start Time | 05:21 PM |
| End Date | 16/02/2023 |
| End Time | 05:06 PM |
| SAIDI value of major event before replacement | 75.0459 |
| SAIDI value of major event | 0.481 |
| SAIFI value of major event before replacement | 0.0925 |
| SAIFI value of major event | 0.0144 |
| Location of SAIDI major event | Kopuaroa, Eastcoast & Potaka |
| Main equipment involved in SAIDI major event | Tripped CB found nothing |
| How Eastland Network responded to the event | Because the 50kV line faulted, the coast was running on the generators, any feeder fault causes the generators to trip. This takes out a large number of customers because all feeders from the substation lose power. The process in not to reclose on the generator after a fault so it takes longer to restore as a patrol is necessary. Patrolled line and found nothing so restored power. |
| Mitigating factors that may have prevented or minimised the major event | The coast network was running off generators because of a 50kV fault. |
| Steps taken to mitigate the risk of future major events | Followed process, so it took the appropriate time to restore power, just had large numbers off. |

| SAIDI Information | |
|---|---|
| Cause | Poles down - Cyclone Gabrielle |
| Start Date | 14/02/2023 |
| Start Time | 03:16 AM |
| End Date | 2/03/2023 |
| End Time | 04:53 PM |
| SAIDI value of major event before replacement | 38.6738 |
| SAIDI value of major event | 0.2480 |
| Location of SAIDI major event | Matawai |
| Main equipment involved in SAIDI major event | Poles down |
| How Eastland Network responded to the event | Fault at start of feeder with many customers. Pole in flooded riverbank could not access immediately. Rediverted feed through 50kV line. |
| Mitigating factors that may have prevented or minimised the major event | Access prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| 1/48th of the SAIDI unplanned boundary value | 14/02/2023 to 15/02/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 14/02/2023 16:00 | 13.234 | 0.273 |
| 0.27 | 14/02/2023 19:30 | 0.083 | 0.083 |
| 0.27 | 15/02/2023 10:00 | 0.003 | 0.003 |
| 0.27 | 15/02/2023 10:30 | 0.009 | 0.009 |
| 0.27 | 15/02/2023 11:30 | 6.580 | 0.273 |
| Total | | 19.909 | 0.641 |

| SAIDI Information | |
|---|--|
| Cause | Trees through line - GAB |
| Start Date | 13/02/2023 |
| Start Time | 05:25 PM |
| End Date | 27/02/2023 |
| End Time | 01:26 PM |
| SAIDI value of major event before replacement | 82.8524 |
| SAIDI value of major event | 0.4258 |
| Location of SAIDI major event | Raupunga, Kotemaori, Putere |
| Main equipment involved in SAIDI major event | 11kV wires down |
| How Eastland Network responded to the event | Trees through the line at the start of the Raupunga Feeder. No access, large numbers because normal back feed (Frasertown) not available. Limited ability to restore power to everyone until fault was fixed. Access was not available for four days with large number of consumers off. |
| Mitigating factors that may have prevented or minimised the major event | If we had road access or back up feed had not failed and power would have been restored earlier. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| 1/48th of the SAIDI unplanned boundary value | 15/02/2023 to 16/02/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIDI value for Class C interruption | Normalised SAIDI value for Class C interruption |
| 0.27 | 15/02/2023 14:30 | 6.410 | 0.273 |
| 0.27 | 15/02/2023 23:00 | 4.670 | 0.273 |
| 0.27 | 16/02/2023 9:30 | 0.028 | 0.028 |
| 0.27 | 16/02/2023 13:30 | 2.989 | 0.273 |
| 0.27 | 16/02/2023 14:00 | 0.258 | 0.258 |
| Total | | 14.355 | 1.105 |

| SAIDI Information | |
|---|---|
| Cause | Car vs pole- Smashed it, tripped out feeder, isolated, repaired daylight |
| Start Date | 15/02/2023 |
| Start Time | 11:12 PM |
| End Date | 16/02/2023 |
| End Time | 03:09 PM |
| SAIDI value of major event before replacement | 4.9278 |
| SAIDI value of major event | 0.3793 |
| Location of SAIDI major event | Riverside Rd |
| Main equipment involved in SAIDI major event | 11kV Pole |
| How Eastland Network responded to the event | Car Vs pole - major town feeder. Occurred late at night, not all restored until the pole was replaced the next day. |
| Mitigating factors that may have prevented or minimised the major event | The location of the fault made temporary restoration difficult. Could not restore power to all consumers overnight. |
| Steps taken to mitigate the risk of future major events | When the pole is due for replacement look at other options eg undergrounding. |

| SAIDI Information | |
|---|--|
| Cause | Wires down -GAB |
| Start Date | 13/02/2023 |
| Start Time | 10:31 PM |
| End Date | 16/02/2023 |
| End Time | 03:35 PM |
| SAIDI value of major event before replacement | 9.1260 |
| SAIDI value of major event | 0.4933 |
| Location of SAIDI major event | Mahia |
| Main equipment involved in SAIDI major event | 11kV Wires |
| How Eastland Network responded to the event | Large spur line, no access to find fault, so permanent generator not started until fault found. |
| Mitigating factors that may have prevented or minimised the major event | Access prevented earlier restoration. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

| SAIDI Information | |
|---|--|
| Cause | Replair broken wire, replace broken pole GAB |
| Start Date | 16/02/2023 |
| Start Time | 01:55 PM |
| End Date | 20/02/2023 |
| End Time | 06:29 PM |
| SAIDI value of major event before replacement | 2.9885 |
| SAIDI value of major event | 0.2300 |
| Location of SAIDI major event | Morere |
| Main equipment involved in SAIDI major event | 11kV wire and Pole |
| How Eastland Network responded to the event | Spur line with no back feed and access an issues. Could not restore until access could be gained on State Highway. |
| Mitigating factors that may have prevented or minimised the major event | If we had road access power would have been restored earlier. |
| Steps taken to mitigate the risk of future major events | This is a major weather event- Cyclone Gabrielle, caused multiple faults and limited access, which are beyond our control. |

Table 22

| Normalisation of unplanned SAIFI major events RY23 | | | |
|--|--------------------------|--|---|
| SAIFI unplanned boundary value | | | 0.1765 |
| 1/48th of the SAIFI unplanned boundary value | 19/08/2022 to 20/08/2022 | | |
| | Half hour commencing | Raw SAIFI value for Class C interruption | Normalised SAIFI value for Class C interruption |
| 0.00 | 19/08/2022 15:30 | 0.8112 | 0.004 |
| 0.00 | 20/08/2022 6:30 | 0.0028 | 0.003 |
| 0.00 | 20/08/2022 10:30 | 0.0096 | 0.004 |
| 0.00 | 20/08/2022 11:00 | 0.0035 | 0.004 |
| Total | | 0.8272 | 0.015 |

| SAIFI Major Event Information | |
|---|--|
| Cause | Suspect caused extremely high wind gust Tuai Region |
| Start Date | 19/08/2022 |
| Start Time | 03:34 PM |
| End Date | 19/08/2022 |
| End Time | 03:47 PM |
| SAIFI value of major event before replacement | 0.8112 |
| SAIFI value of major event | 0.0148 |
| Location of SAIFI major event | All Gis Sub |
| Main equipment involved in SAIFI major event | Conductor Clashing |
| How Eastland Network responded to the event | 33kV Line tripped - high winds. Restored power, held for 2 minutes and re tripped. Decided not to reclose again and went to start Mahia generator, which failed (later found to be a faulty fuel valve). Went to close W8816 to bring on Morere, it failed to close. Sent contractor from Gisborne to start generator and manually close W8816. When restoring power to Mahia via generator 2 x 11kV additional faults occurred while power was out. Jumper was off at W958 and Wires down by Opoutama. Repaired next day. |
| Mitigating factors that may have prevented or minimised the major event | An abnormal mechanical fault on the automated switch was not found. The generator failed to start. |
| Steps taken to mitigate the risk of future major events | Service the switch and reconfigure the generator valve. Patrolled line in light of day no faults found. |

| 1/48th of the SAIFI unplanned boundary value | 10/01/2023 to 11/01/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIFI value for Class C interruption | Normalised SAIFI value for Class C interruption |
| 0.00 | 10/01/2023 5:00 | 0.0102 | 0.004 |
| 0.00 | 10/01/2023 5:30 | 0.0056 | 0.004 |
| 0.00 | 10/01/2023 8:30 | 0.0007 | 0.001 |
| 0.00 | 10/01/2023 11:00 | 0.0000 | 0.000 |
| 0.00 | 10/01/2023 11:30 | 0.0014 | 0.001 |
| 0.00 | 10/01/2023 14:30 | 0.0049 | 0.004 |
| 0.00 | 10/01/2023 18:00 | 0.0034 | 0.003 |
| 0.00 | 10/01/2023 19:00 | 0.0611 | 0.004 |
| 0.00 | 10/01/2023 20:00 | 0.0256 | 0.004 |
| 0.00 | 10/01/2023 21:00 | 0.0361 | 0.004 |
| 0.00 | 10/01/2023 23:00 | 0.0033 | 0.003 |
| 0.00 | 11/01/2023 0:30 | 0.0280 | 0.004 |
| Total | | 0.1803 | 0.035 |

| SAIFI Major Event Information | |
|---|---|
| Cause | Tree through 50kV line (Cyclone Hale) |
| Start Date | 10/01/2023 |
| Start Time | 07:22 AM |
| End Date | 13/01/2023 |
| End Time | 03:06 PM |
| SAIFI value of major event before replacement | 0.0870 |
| SAIFI value of major event | 0.0132 |
| Location of SAIFI major event | Tiki Tiki |
| Main equipment involved in SAIFI major event | 50kV and 11kV lines |
| How Eastland Network responded to the event | 50Kv tripped, got Ruatoria and Te Araroa generators running and power restored, Then the tree went through the 50kV line and dropped onto the 11kV line, tripping the Te Araroa generator. Then isolated lines to find fault, took a while to find fault as it occurred at 9 pm and didn't find till the next day and found a second fault on 11kV (tree online). Made repairs and put it back to normal. |
| Mitigating factors that may have prevented or minimised the major event | Resources, Trees and Cyclone Hale were contributing factors. Safety didn't allow faultman to start fault finding until next day. |
| Steps taken to mitigate the risk of future major events | Both trees were out of zone, and current regulations don't allow the legal right to cut. The location at the end of the network and getting resources there. |

| 1/48th of the SAIFI unplanned boundary value | 13/02/2023 | | |
|--|----------------------|--|---|
| | Half hour commencing | Raw SAIFI value for Class C interruption | Normalised SAIFI value for Class C interruption |
| 0.00 | 13/02/2023 7:00 | 0.0085 | 0.004 |
| 0.00 | 13/02/2023 8:00 | 0.0043 | 0.004 |
| 0.00 | 13/02/2023 8:30 | 0.0012 | 0.001 |
| 0.00 | 13/02/2023 9:00 | 0.0019 | 0.002 |
| 0.00 | 13/02/2023 10:30 | 0.0026 | 0.003 |
| 0.00 | 13/02/2023 11:00 | 0.0000 | 0.000 |
| 0.00 | 13/02/2023 11:30 | 0.0022 | 0.002 |
| 0.00 | 13/02/2023 12:00 | 0.0020 | 0.002 |
| 0.00 | 13/02/2023 14:00 | 0.0003 | 0.000 |
| 0.00 | 13/02/2023 14:30 | 0.0300 | 0.004 |
| 0.00 | 13/02/2023 15:00 | 0.0081 | 0.004 |
| 0.00 | 13/02/2023 15:30 | 0.0002 | 0.000 |
| 0.00 | 13/02/2023 16:00 | 0.0121 | 0.004 |
| 0.00 | 13/02/2023 16:30 | 0.0071 | 0.004 |
| 0.00 | 13/02/2023 17:00 | 0.0557 | 0.004 |
| 0.00 | 13/02/2023 17:30 | 0.0036 | 0.004 |
| 0.00 | 13/02/2023 18:00 | 0.0026 | 0.003 |
| 0.00 | 13/02/2023 18:30 | 0.0120 | 0.004 |
| 0.00 | 13/02/2023 19:00 | 0.0255 | 0.004 |
| 0.00 | 13/02/2023 19:30 | 0.0074 | 0.004 |
| 0.00 | 13/02/2023 20:00 | 0.0074 | 0.004 |
| 0.00 | 13/02/2023 20:30 | 0.0462 | 0.004 |
| Total | | 0.2408 | 0.061 |


| SAIDI and SAIFI Information | |
|---|---|
| Cause | Multiple feeder faults/tripping from mains & Gen including 50kV and 11kV |
| Start Date | 13/02/2023 |
| Start Time | 05:21 PM |
| End Date | 16/02/2023 |
| End Time | 05:06 PM |
| SAIDI value of major event before replacement | 75.0459 |
| SAIDI value of major event | 0.481 |
| SAIFI value of major event before replacement | 0.0925 |
| SAIFI value of major event | 0.0144 |
| Location of SAIDI major event | Kopuaroa, Eastcoast & Potaka |
| Main equipment involved in SAIDI major event | Tripped CB found nothing |
| How Eastland Network responded to the event | Because the 50kv line faulted, the coast was running on the generators, any feeder fault causes the generators to trip. This takes out a large number of customers because all feeders from the substation lose power. The process is not to reclose on the generator after a fault so it takes longer to restore as a patrol is necessary. Patrolled line and found nothing so restored power. |
| Mitigating factors that may have prevented or minimised the major event | The coast network was running off generators because of a 50kV fault. |
| Steps taken to mitigate the risk of future major events | Followed process, so it took the appropriate time to restore power, just had large numbers off. |

| 1/48th of the SAIFI unplanned boundary value | 13/02/2023 to 14/02/2023 | | |
|--|--------------------------|--|---|
| | Half hour commencing | Raw SAIFI value for Class C interruption | Normalised SAIFI value for Class C interruption |
| 0.00 | 13/02/2023 21:00 | 0.0031 | 0.003 |
| 0.00 | 13/02/2023 21:30 | 0.0356 | 0.004 |
| 0.00 | 13/02/2023 22:00 | 0.0210 | 0.004 |
| 0.00 | 13/02/2023 22:30 | 0.8282 | 0.004 |
| 0.00 | 13/02/2023 23:00 | 0.0107 | 0.004 |
| 0.00 | 13/02/2023 23:30 | 0.0061 | 0.004 |
| 0.00 | 14/02/2023 0:00 | 0.0050 | 0.004 |
| 0.00 | 14/02/2023 2:00 | 0.0058 | 0.004 |
| 0.00 | 14/02/2023 2:30 | 0.0224 | 0.004 |
| 0.00 | 14/02/2023 3:00 | 0.0153 | 0.004 |
| 0.00 | 14/02/2023 3:30 | 0.0037 | 0.004 |
| 0.00 | 14/02/2023 5:30 | 0.0019 | 0.002 |
| 0.00 | 14/02/2023 6:30 | 0.0398 | 0.004 |
| 0.00 | 14/02/2023 8:30 | 0.0028 | 0.003 |
| 0.00 | 14/02/2023 16:00 | 0.0031 | 0.003 |
| 0.00 | 14/02/2023 19:30 | 0.0072 | 0.004 |
| Total | | 1.0118 | 0.055 |

| SAIDI and SAIFI Information | |
|---|---|
| Cause | Cyclone Gabrielle caused conductor to clash |
| Start Date | 13/02/2023 |
| Start Time | 10:46 PM |
| End Date | 13/02/2023 |
| End Time | 11:31 PM |
| SAIDI value of major event before replacement | 36.5036 |
| SAIDI value of major event | 0.2341 |
| SAIFI value of major event before replacement | 0.8112 |
| SAIFI value of major event | 0.0441 |
| Location of SAIDI major event | All Gisborne & East Coast |
| Main equipment involved in SAIDI major event | 110kV Wires clashing |
| How Eastland Network responded to the event | We initiated the network 110kV outage procedure by analysing the SCADA data from the fault. It was ascertained it was a phase to phase on both circuits clashing. We could then close circuit back in within 45 minutes |
| Mitigating factors that may have prevented or minimised the major event | We have changed the phasing so the clashes are phase to phase and the circuit can be reclosed without patrolling. Reducing the outage time considerably. |
| Steps taken to mitigate the risk of future major events | Created the process above to minimise when this occurs as a result of extreme weather events. |

Appendix E – Director’s certificate

We Mark Adrian Ratcliffe and Fiona Ann Oliver, being directors of Firstlight Network Limited certify that, having made all reasonable enquiry, to the best of our knowledge and belief, the attached Annual Compliance Statement of Firstlight Network Limited, and related information, prepared for the purposes of the *Electricity Distribution Services Default Price-Quality Path Determination 2020* has been prepared in accordance with all relevant requirements.



Director: Mark Adrian Ratcliffe



Director: Fiona Ann Oliver

25 August 2023

Date

25 August 2023

Date

Note: Section 103(2) of the Commerce Act 1986 provides that no person shall attempt to deceive or knowingly mislead the Commission in relation to any matter before it. It is an offence to contravene section 103(2) and any person who does so is liable on summary conviction to a fine not exceeding \$100,000 in the case of an individual or \$300,000 in the case of a body corporate.

Independent Assurance Report to the Directors of Firstlight Network Limited on the Annual Compliance Statement for the Assessment Period Ended 31 March 2023 as required by the Electricity Distribution Services Default Price-Quality Path Determination 2020 (Consolidated 20 May 2020)

The Auditor-General is the auditor of Firstlight Network Limited (the company) (formerly “Eastland Network Limited”) . The Auditor-General has appointed me, Brett Tomkins, using the staff and resources of Deloitte Limited, to undertake a reasonable assurance engagement, on his behalf, on whether the Annual Compliance Statement on pages 4 to 12 and 13 to 40 for the assessment period ended on 31 March 2023 has been prepared, in all material respects, in compliance with the Electricity Distribution Services Default Price-Quality Path Determination 2020 (consolidated 20 May 2020) (the Determination).

Opinion

In our opinion, in all material respects:

- as far as appears from our examination, the information used in the preparation of the Annual Compliance Statement has been properly extracted from the company’s accounting and other records, sourced from its financial and non-financial systems; and
- the company has complied with clauses 11.5 and 11.6 of the Determination in preparing the Annual Compliance Statement for the assessment period ended 31 March 2023.

Basis for opinion

We conducted our engagement in accordance with the Standard on Assurance Engagements (SAE) 3100 (Revised) Compliance Engagements (“SAE 3100 (Revised)”), issued by the New Zealand Auditing and Assurance Standards Board. An engagement conducted in accordance with SAE 3100 (Revised) requires that we also comply with the International Standard on Assurance Engagements (New Zealand) 3000 (Revised) Assurance Engagements Other Than Audits or Reviews of Historical Financial Information.

We have obtained sufficient recorded evidence and explanations that we required to provide a basis for our opinion.

Directors’ responsibilities

The directors of the company are responsible for the:

- preparation of the Annual Compliance Statement under clause 11.4 and in accordance with the requirements in clauses 11.5 and 11.6 of the Determination; and
- identification of risks that may threaten compliance with the clauses identified above and controls which will mitigate those risks and monitor ongoing compliance.

Auditor’s responsibilities

Our responsibilities in terms of clause 11.5(e) and schedule 8(1)(b)(vi) and 8(1)(c) of the Determination, are to express an opinion on whether:

- as far as appears from our examination, the information used in the preparation of the Annual Compliance Statement has been properly extracted from the company’s accounting and other records, sourced from its financial and non-financial systems; and
- the Annual Compliance Statement, for the assessment period ended 31 March 2023, has been prepared, in all material respects, in accordance with the requirements in clauses 11.5 and 11.6 of the Determination.

To meet these responsibilities, we planned and performed procedures in accordance with SAE 3100 (Revised), to obtain reasonable assurance about whether the company has complied, in all material respects, with clauses 11.5 and 11.6 of the Determination.

In relation to the wash-up amount set out in clause 8.6 of the Determination, our procedures included recalculation of the wash-up amount in accordance with schedule 1.6 of the Determination and assessing it against the amounts and disclosures contained on pages 4 to 7 of the Annual Compliance Statement.



In relation to the quality standards in clause 9 of the Determination, our procedures included examination, on a test basis, of evidence relevant to the values and disclosures contained on pages 8 to 13 of the Annual Compliance Statement.

In relation to the quality incentive adjustment set out in Schedule 4 of the Determination, our procedures included recalculation of the quality incentive adjustment in accordance with Schedule 4 of the Determination and assessing it against the amounts and disclosures contained on pages 12 to 13 of the Annual Compliance Statement.

An assurance engagement to report on the company's compliance with the Determination involves performing procedures to obtain evidence about the compliance activity and controls implemented to meet the requirements. The procedures selected depend on our judgement, including the identification and assessment of the risks of material non-compliance with the requirements.

Inherent limitations

Because of the inherent limitations of an assurance engagement, together with the internal control structure, it is possible that fraud, error or non-compliance with clauses 11.5 and 11.6 of the Determination may occur and not be detected. A reasonable assurance engagement throughout the assessment period does not provide assurance on whether compliance with clauses 11.5 and 11.6 of the Determination will continue in the future.

Restricted use

This report is provided solely for your exclusive use and solely for the purpose of Clause 11.5(e) of the Determination. However, we understand that a copy of this report has been requested by the Commerce Commission solely for the purpose above. We agree that a copy of our report may be provided to the Commerce Commission. This report is not to be used for any other purpose, recited or referred to in any document, copied or made available (in whole or in part) to any other person without our prior written consent. We accept or assume no duty, responsibility or liability to any party, other than you, in connection with the report or this engagement including without limitation, liability for negligence in relation to the opinion expressed in our report.

Independence and quality control

We complied with the Auditor-General's:

- independence and other ethical requirements, which incorporate the requirements of Professional and Ethical Standard 1 International Code of Ethics for Assurance Practitioners (Including International Independence Standards) (New Zealand) (PES 1) issued by the New Zealand Auditing and Assurance Standards Board; and
- quality management requirements, which incorporate Professional and Ethical Standard 3 Quality Management for Firms that perform Audits or Reviews of Financial Statements, or other Assurance or Related Services Engagements (PES 3) issued by the New Zealand Auditing and Assurance Standards Board. PES 3 requires our firm to design, implement and operate a system of quality management including policies or procedures regarding compliance with ethical requirements, professional standards and applicable legal and regulatory requirements.

The Auditor-General, and his employees, Deloitte Limited and its partners and employees may deal with the company¹ on normal terms within the ordinary course of trading activities of the company. Other than any dealings on normal terms within the ordinary course of trading activities of the company, this engagement², the assurance engagement on the Information Disclosures and the annual audit of the company's financial statements and performance information, we have no relationship with, or interests in, the company.³

Deloitte Limited

Brett Tomkins

Partner

for Deloitte Limited

On behalf of the Auditor-General

Auckland, New Zealand

25 August 2023